

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes storm-drainage piping inside the building and to locations indicated.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Piping Above and Below Grade: Cast Iron Soil Pipe; ASTM A-888 & ASTM A-74, hubless, iron castings with smooth interior walls, uniformly coated with suitable adherent material and Cast Iron Fittings ASTM A888 & ASTM A-74, hubless, cast iron castings conforming to properties and dimensions specified.
- B. Corrosion Protection for Piping Below Grade: Polyethylene Encasement; AWWA C105: Polyethylene film conforming to ASTM D-1248 and installed per 5-S-4.2.1, Method "A".

PART 3 - EXECUTION

3.1 GENERAL

- A. As required by the Engineer and code.
- B. Pressure test in accordance with Section 723, 2010 CPC.

END OF SECTION