

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes through-penetration firestop systems for penetrations through the following fire-resistance-rated assemblies, including both empty openings and openings containing penetrating items:
 - 1. Floors.
 - 2. Roofs.
 - 3. Walls and partitions.
 - 4. Smoke barriers.
 - 5. Construction enclosing compartmentalized areas.
 - 6. Penetrations through a single membrane of fire-resistance-rated floor, roof, and wall assemblies.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. Hilti Construction Chemicals, Inc.
 - 2. 3M Fire Protection Products.
 - 3. Or equal.
- B. All fire stopping and caulking materials to be the same color throughout.

PART 3 - EXECUTION

3.1 GENERAL

- A. As required by the manufacturer and approved by the State Fire Marshal.
- B. All subcontractors shall use firestop systems from one manufacturer.
- C. UL firestop label designations shall be placed where installed in field locations.
- D. Provide product listing on site and available for inspector for each specific application.

END OF SECTION