

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes acoustical panels and exposed suspension systems for ceilings.

1.2 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install acoustical panel ceilings until spaces are enclosed and weatherproof, wet-work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.

1.3 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed, are packaged with protective covering for storage, and are identified with labels describing contents.
 - 1. Acoustical Ceiling Units: Full-size units equal to 2.0 percent of amount installed.
 - 2. Suspension System Components: Quantity of each exposed component equal to 2.0 percent of amount installed.

PART 2 - PRODUCTS

2.1 MATERAILS

- A. As required by the Design/Builder.

PART 3 - EXECUTION

3.1 GENERAL

- A. As required by the manufacturer and Design/Builder.
- B. Provide 3" clear space above top of grid to enable removal of tile.

3.2 FIELD QUALITY CONTROL

- A. Testing Agency: The University will engage a qualified independent testing agency to perform field quality-control testing

END OF SECTION