

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Back-mounted acoustical wall panels.

1.2 QUALITY ASSURANCE

- A. Fire-Test-Response Characteristics: Provide acoustical wall panels with the following surface-burning characteristics as determined by testing identical products per UBC Standard 8-1 (based on ASTM E 84-91a) by UL or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify acoustical wall panels with appropriate markings of applicable testing and inspecting agency.
 - 1. Flame Spread: 25 or less.
 - 2. Smoke Developed: 450 or less.

1.3 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install acoustical wall panels until construction in spaces is complete and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- B. Air-Quality Limitations: Protect acoustical wall panels from exposure to airborne odors, such as tobacco smoke, and install panels under conditions free from odor contamination of ambient air.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. As required by the Design/Builder.

PART 3 - EXECUTION

3.1 GENERAL

- A. As required by the Design/Builder and manufacturer to maintain warranty.

END OF SECTION