

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following fire-suppression piping inside the building:
 - 1. Manual dry-type, Class I standpipe systems.
 - 2. Wet-pipe sprinkler systems.

1.2 SUBMITTALS

- A. As required for approval by the State Fire Marshal.

1.3 EXTRA MATERIALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Sprinkler Cabinets: Finished, wall-mounting, steel cabinet with hinged cover, with space for minimum of six spare sprinklers plus sprinkler wrench. Include number of sprinklers required by NFPA 13 and sprinkler wrench. Include separate cabinet with sprinklers and wrench for each type of sprinkler on Project.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. As required for approval by the State Fire Marshal. Piping shall be Victaulic, not groove lock type piping.

2.2 SPRINKLERS

- A. Manufacturers:
 - 1. Central Sprinkler Corp.
 - 2. Grinnell Fire Protection.
 - 3. Star Sprinkler Inc.
 - 4. Viking Corp.

PART 3 - EXECUTION

3.1 GENERAL

- A. As required for approval by the State Fire Marshal.

END OF SECTION