

PART 1 - GENERAL

1.1 SUMMARY

- A. Submit data/catalog cuts for each type of product.
- B. Each panel shall be tested by qualified third party testing agent prior to acceptance.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Panel boards shall be copper bussing with bolt-on type circuit breakers. Breakers serving life-safety load such as fire alarm shall be red in color and have handle lock. All panels shall be fully rated to withstand the anticipated maximum fault current.
- B. Acceptable manufacturers shall be General Electric, Siemens, Square D, or equal.

PART 3 - EXECUTION

3.1 GENERAL

- A. Install panel boards in accordance with manufacturer's written instructions to maintain warranty.
- B. Provide 2 – 3/4" stub-ups for future use. Conduits shall terminate above ceiling area or 10' wherever practical.
- C. All installations shall adhere to the requirements of the current edition of the CEC.
- D. Provide type written schedules in each panel.

END OF SECTION