

BMP G03 - General Campus/Ground Inspections

Inspections will focus on spills, leaks or conditions that could lead to discharges of pollutants to the storm water conveyance system. Locations with high priority hotspots will be inspected at least quarterly (see Section 9.5). Other areas of lower priority locations will be checked less frequently, but no less than once every five years (Phase II Permit term).

Refer to the appendices for SWMP Section 9 for facility inventory and high priority hotspot designation, facility map, storm water facility inspection form, and facility inspection tracking sheet.

